

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7271-0082:106 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Rauland-Borg, 3450 W. Oakton Street, Skokie, IL 60076  
Contact: Daryl Miceli (708) 679-0900

DESIGN: Model FA202 smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as ionization smoke detector for use with separately listed compatible fire alarm control unit when used in conjunction with listee's compatible bases Model FA200 and FA210 (CSFM Listing No. 7300-0082:105\*).

XLF: 7271-0410-135

\*Corrected 07-31-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager